



Advocate Nomalanga Sithole
Chief Executive Officer
National Energy Regulator of SA
P O Box 40343
Arcadia
0007

Date: 23/01/2024

Fax: 012-401 4700

Attention: Tshepo Ramokoka

Dear Adv. Sithole

APPLICATION FOR AMENDMENT OF ESKOM ELECTRICITY DISTRIBUTION LICENCE TO INCLUDE WARDEN AND EZENZELENI

The municipal council of Phumelela took a resolution (as attached) to hand-over the supply of electricity of Warden and Ezenzeleni to Eskom. It is against this back that Eskom herewith applies for amendment of its existing electricity distribution license no. **NER/D/Eskom** to include Warden and Ezenzeleni in its schedule 1 (list of areas of supply).

Warden Town is situated at Lat (S) 27° 51' 17.4 Lon (E) 28° 57' 53.2" and Ezenzeleni at Lat (S) 27° 50' 8.9" Lon (E) 28° 58' 32.9". It is regarded as a brownfield area in Phumelela. Eskom is supplying 2373 customers in Memel and Vrede which is part of the Phumelela municipality.

The takeover area consists of approximately 3 500 residential customers with total planned notified maximum demand of 3.5 MVA. The area will be supplied from the Warden substation with an installed capacity of 2.0 MVA [22kV line on Ruraflex tariff] for Ezenzeleni and 1.5 MVA [11kV line with Miniflex tariff] for Warden. [Single line diagram attached.]

Notification of the affected customers by adverts in 2 (two) local newspapers circulating as per Section 11 of Electricity Regulation Act, 2006 (Act No. 4 of 2006) will be done after all necessary information and documentation has been submitted to NERSA in support of this application and on agreement with NERSA.

A handwritten signature in black ink, appearing to be 'S. Sithole'.

This application was discussed and approved at the Eskom DLRC meeting held on 7th August 2023. An extract of the minutes is attached as Annexure 3.

The tariffs to this development will be Eskom's Nersa approved tariffs.

Yours faithfully



Agnes Mlambo
General Manager, Distribution
CENTRALEAST Cluster

ENCLOSED

1. Copy of the nodal map(s) or polygons of the area to be applied for
2. Single line diagram
3. Minutes of the meeting (Dexco).
4. Inspection in loco form
5. Municipal Council Resolution Number 13/08/2022